

Atmospheric Tank Failures Mechanisms and an Unexpected Case

**12th Global Congress on
Process Safety
Houston – April 2016**



BLUEFIELD
PROCESS SAFETY

Mike Schmidt bio

- ❖ **Principal of Bluefield Process Safety since 2008**
- ❖ **Joined Union Carbide in 1977**
- ❖ **Began work in process safety following tragedy in Bhopal in 1984**
- ❖ **Joined faculty at Missouri S&T in Rolla in 2009, teaching on safety and risk**
- ❖ **Work includes**
 - ◆ **Facilitating PHAs, LOPAs, RTC establishment**
 - ◆ **SIS conceptual design, SIL verification calcs**
 - ◆ **PSM compliance and audits**

Atmospheric Tank Failures Mechanisms and an Unexpected Case

**12th Global Congress on
Process Safety
Houston – April 2016**



BLUEFIELD
PROCESS SAFETY

Presented by

❖ **Michael S. Schmidt**

- ◆ **Principal,
Bluefield Process Safety, LLC
St. Louis, Missouri**
- ◆ **Adjunct Professor,
Missouri University of Science and
Technology
Rolla, Missouri**

Atmospheric tanks

- ❖ **Not a consensus on definition, but consensus is not critical**
 - ◆ **Operate at < 1 psig (< 30 in H_2O)**
 - ◆ **Do not operate under vacuum**
- ❖ **Typical worries:**
 - ◆ **Flammable hazards**
 - ◆ **Overfilling**
 - ◆ **Leaks**



Catastrophic atm. tank failures

- ❖ **Collapse**
- ❖ **Implosion**
- ❖ **Explosion**



Collapse

- ❖ Walls or joints fail locally, and then come “unzipped”
- ❖ Result from:
 - ◆ Inadequate design or construction
 - ◆ Converted to different service
 - ◆ Tank deteriorates over time



Implosion

- ❖ **Do not produce shock waves or flying shrapnel**
- ❖ **May be breached, but loss typically not significant**
- ❖ **Result from exposure to vacuum**
 - ◆ **Vacuum pumps**
 - ◆ **Vacuum jets**
 - ◆ **Pump out**
 - ◆ **Gravity drain**
 - ◆ **Condensing vapor**



Explosion

- ❖ **Internal pressure exceeds capability of tank to withstand**
- ❖ **Result from**
 - ◆ Heating that causes increased vapor pressure
 - ◆ Connection to “high pressure” external sources (feed lines, utilities)
- ❖ **Combined with inadequate venting**

Exceeds capability to withstand

- ❖ **Atmospheric tanks are designed operate at ~ 1 psig**
- ❖ **Vapor pressure of water increases by 5 psi when heated from 80°F to 165°F**
- ❖ **Dead head pressure of pumps is typically well over 1 psig**
- ❖ **Utilities (city water, plant air) are typically in the range of 30 to 100 psig**

A case study



The incident

- ❖ **Blowing out transfer line from caustic storage tank to day tank**
- ❖ **Caustic day tank failed**
- ❖ **Tank head flew ~125', coming down through nearby process building roof**
- ❖ **Employee fell during evacuation and received medical treatment**

Caustic Day Tank head, after...

- ❖ **...coming down through roof of a nearby process building.**



Process background - equipment

- ❖ **50% caustic solution**
- ❖ **3" stainless steel transfer line**
- ❖ **50% caustic entered tank through dip pipe from top of day tank**
- ❖ **Day tank equipped with 3" PVC goose neck vent**

Process background - transfer

❖ **Transfer:**

- ◆ **50% caustic transferred from storage tank to day tank**
- ◆ **Transfer line blown clear with process air for 15 min**

❖ **Purge for maintenance, also:**

- ◆ **Transfer line flushed with city water for 5 min**
- ◆ **Water blown from transfer line with process air for 15 min**

Incident time line

Balmy, spring Friday morning

- ❖ **~9:30 am - Prep for maintenance on leaking line by purging w/air**
- ❖ **~9:50 am - Line purged with city water**
- ❖ **~10:00 am - Disconnected water line; operator called away**
- ❖ **~10:30 am - Air purge reconnected and started**
- ❖ **11:10:19 - Day Tank explodes**

Generic issues for caustic tanks

- ❖ **Sources of high pressure**
 - ◆ Material incompatibilities → H₂
 - ◆ High pressure utilities
 - ◆ Pump deadhead
 - ◆ Heating frozen caustic
- ❖ **Causes of blockage**
 - ◆ Valves inadvertently closed
 - ◆ Frozen caustic
 - ◆ Vermin nesting
- ❖ **Failure below design pressure**
 - ◆ Exceeding design temp for MoC
 - ◆ Unsupported piping (esp. PVC)

Conditions at incident scene

❖ **Noted from video**

- ◆ **Video shuddered, confirming explosion and shockwave**
- ◆ **Cloud dispersed immediately-no BLEVE, no ignition, no boil-up**
- ◆ **Head separated first on west side and then was propelled east**

❖ **Noted from field**

- ◆ **Air at 90 psig, city water at 40 psig**

Also noted from field

- ❖ **Though not visible from outside of tank, vent was encrusted with NaOH, choking off vent to less than 1/2"**



Also noted from field

- ❖ **Separation was at weak seam weld**
- ❖ **Tank interior showed some staining, but no build-up like that in the vent nozzle**



Contributing factors

- ❖ **Direct cause – Source of high pressure was 90 psig process air used to blow down line**
- ❖ **Indirect cause – Plugged vent, (extended time allowed to blow did not help, but eventually would not have mattered)**
- ❖ **Basic causes – High pressure blow down, dip pipe that extended into liquid, inspection method**

Case recommendations

- ❖ **Assure vent is adequate**
 - ◆ **Dow recommends vent area be 4 times fill line area, and that vent extend to within 3' of ground**
- ❖ **Vent inspection to catch build-up**
 - ◆ **Caustic mist generated by blowing line clear will plug vent**
 - ◆ **Consider boroscopes or inspection ports**
- ❖ **Remove dip pipe**
- ❖ **Regulate inlet pressures to as low as possible**

General recommendations

- ❖ **Regarding catastrophic collapse**
- ❖ **Regarding catastrophic implosion**
- ❖ **Regarding catastrophic explosion**
- ❖ **Regarding use of dip pipes**



Regarding catastrophic collapse

- ❖ **Apply rigorous MOC procedures when changing service, especially changes in density**
- ❖ **Act as though you know a tank is going to fail while being commissioned**
- ❖ **Pay attention to wall thinning, general *and* localized, during use. Pay special attention to potential points of erosion.**

Regarding catastrophic implosion

❖ **Control sources of vacuum**

- ◆ **Vacuum pumps**
- ◆ **Steam vacuum jets**
- ◆ **Pump out**
- ◆ **Gravity draining**
- ◆ **Condensing vapors**

❖ **Validate vacuum relief works**

- ◆ **Atmospheric vents**
- ◆ **Conservations vents**
- ◆ **Inerting pads**
- ◆ **Vacuum breakers**


Regarding catastrophic explosion

In addition to obvious concerns about flammability

- ❖ **Control sources of pressure**
 - ◆ High inlet gas pressure
 - ◆ High inlet liquid pressure
 - ◆ Heating
- ❖ **Assure venting is adequate**
 - ◆ Properly designed
 - ◆ Inspected, tested, and maintained

Regarding use of dip pipes

- ❖ **Use dip pipes for non-polar, flammable liquids, to avoid static discharge**
- ❖ **Avoid dip pipes for aqueous solutions of dissolved solids, which will lead to misting and deposits when blown out**



General conclusions

- ❖ **Atmospheric tanks are relatively fragile**
- ❖ **Often overlooked as hazards**
- ❖ **Often neglected as a maintenance priority**
- ❖ **HazOp response to “pressure-too high” or “pressure-too low” cannot be, “That can’t happen, we’re open to atmosphere.”**

Questions?

